R=SU 6.5

6.5kWh Battery Pack Specification



DATE

(1) LG Chem

Revision Date: Oct. 21. 2016

MODEL P/N

48V 6.5kWh: R48126P3S

CONTENTS

1. Features	 2
2. Outline Dimensions	 2
3. Technical Data	 3
4. Product Composition	 4
5. LED indicators	 4
6. Packaging	 5
7. General Precautions	 7
8. Battery Handling Guide	 8
9. Response to Emergency Situations	 9
10. Troubleshootina	 10

INTRODUCTION



1. Features

RESU 6.5 battery pack designed for photovoltaic systems is easily adaptable energy storage solution. With RESU Plus, all 48V models can be "cross-connected" with one other 48V unit of any capacity.

- ※ RESU Plus is an expansion kit specially designed for 48V models.
 Number of expandable battery units: up to 2
 - ☐ Compact and light weight
 - ☐ Powerful Performance : World Best Energy Density
 - ☐ Easy and Flexible installation
 - : Easy wall-mounted or floor-standing installation enable
 - : Diverse Matched Inverters Available
 - ☐ BMS firmware can be updated easily by using SD Card

2. Outline Dimensions





Physical Characteristics				
Model P/N		R48126P3S		
Width	mm (in)	452 (17.8)		
Depth	mm (in)	120 (4.7)		
Height mm (in)		656 (25.8)		
Weight	Kg (lb)	52 (114.6)		





3. Technical Data

Electrical Characteristics		
Total Energy Capacity	6.5 kWh	
Usable Energy Capacity	5.9kWh	
Battery Capacity	126 Ah	
Voltage Range	42.0~58.8V _{DC}	
Nominal Voltage	51.8V _{DC}	
Max. Charge/Discharge Current	100A	
Max. Charge/Discharge Power ¹⁾	4.2kW	
Peak Power ²⁾	4.6kW for 3 sec.	
Peak Current	109.5 A for 3 sec.	
Battery Pack Round-Trip Efficiency	>95% (under specific condition)	
Communication Interface CAN 2.0B		
DC Disconnect	Circuit Breaker, Contactor, Fuse	
Operating Conditions		
Installation Location	Indoor(Wall-Mounted) / Outdoor	
Operating Temperature	-10~45°C	
Operating Temperature (Recommended)	15~30°C	
Storage Temperature	-30~60°C	
Humidity	5%~95%	
Altitude	Max. 2,000m	
Cooling Strategy	Natural Convection	

Reliability & Certification				
	Cell	UL1642		
Safety	Battery Pack	CE / RCM / FCC / TUV (IEC 62619) / UL1973		
Hazardous Materials Classification		Class 9		
Transportation		UN38.3 (UNDOT)		
Ingress Rating		IP55		

X Test Conditions - Temperature 25°C


- 1) LG Chem recommends 2.2kW for maximum battery lifetime
- 2) Peak Current excludes repeated short duration (less than 3 sec.) of current pattern.

MECHANICAL DESCRIPTION



4. Product Composition


■ The exploded view



5. LED indicators

The LED indicators on the front of the battery pack show its operating state:

- ON : This indicator is lit when the circuit breaker switch is in the ON position.
- Charging: This indicator is lit while the battery pack is charging.
- Discharging: This indicator is lit while the battery pack is discharging.
- Warning: This indicator is lit when the battery pack is in a warning state.



Oct, 2016 4

PRODUCT PACKAGING



6. Packaging

6-1. Pack Labels



■ Warning Label

Do not discorrect, diseasentia or repair to avoid rigories, sinctic about or hums. Service by sufficient or separate to avoid rigories, sinctic about or hums.

Do not danger or discharge are laterary. If may lead to fine upon a discharge are laterary. If may lead to fine upon a discharge are laterary in may lead to fine upon and enterprise ask out, avoid context with open, soh or cluthes, in event of accident,
Such with water and get medical layer.

Do not discorrect enterprise ask out, avoid context with open, soh or cluthes, in event of accident,
Such with water and get medical layer.

Such and several may content to the or angulation.


Resp the unit water pair form contention or plant. On not book or and if isputs was applied on it.

Resp the unit water pair cluster spring. On a season are liquid. Such ask of the content of the

• Product Spec. & Certification Label

LG CHEM.
MODEL NAME: RESU 6.5
CAPACITY: 126Ah
NOMINAL VOLTAGE: 51.8V
NOMINAL ENERGY: 6.5kWh
Lities ROB
ICP16/102/354/(2P145)E/-10+45/95

■ Serial Label




Oct, 2016 5



The battery Box packaging was approved the International Maritime Dangerous Goods regulation certification. (IMDG Code P903, IATA DGR PI965)

6-2. Box packaging specification


■ Packing Unit



	Size	Weight	Packing	Outer packing
	LxWxH(mm)	(kg)	Qty.	material
Product	656x452x120	52	1	-
Вох	710x670x180	7	1	Corrugated paper
PU *	710x670x180	59	1	Corrugated paper

^{*} PU: Packing Unit

Handling Unit





	Size	Weight	Packing	Outer packing
	L x W x H (mm)	(kg)	Qty.	material
Product	656x452x120	52	10	_
PU	710x670x180	59	10	Corrugated paper
Pallet	720x1,400x120	13	1	Wooden
HU *	720x1,400x1,020	603	1	-

^{*} HU : Handling Unit

40Ft Container Loading Information


R	ESU 6.5		Remark
Container	Pallets	24	-
Loading (ea)	Products	240	240ea/CT = 10ea/Pallet×24Pallets
Weight (ton)		17.47	14,472kg = 603kg/Pallet×24Pallets






20Ft Container Loading Information

R	ESU 6.5		Remark
Container	Pallets	12	-
Loading (ea)	Products	120	120ea/CT = 10ea/Pallet×12Pallets
Weight (ton)		7.23	7,236kg = 603kg/Pallet×12Pallets





Oct, 2016 6

BATTERY SAFETY INSTRUCTIONS



For safety reasons, installers are responsible for familiarizing themselves with the contents of this document and all warnings before performing installation.

7 General Precautions

Failure to observe the precautions described in this section can cause serious injury to persons or damage to property.

■ Risks of explosion

- Do not subject the battery pack to strong impacts.
- Do not crush or puncture the battery pack.
- Do not dispose of the battery pack in a fire.

Risks of fire

- Do not expose the battery pack to temperatures in excess of 60°C.
- Do not place the battery pack near a heat source, such as a fireplace.
- Do not expose the battery pack to direct sunlight.
- Do not allow the battery connectors to touch conductive objects such as wires.

Risks of electrical shock

- Do not disassemble the battery pack
- Do not touch the battery pack with wet hands
- Do not expose the battery pack to moisture or liquids
- Keep the battery pack away from children and animals

• Risks of damage to the battery pack

- Do not allow the battery pack to come in contact with liquids.
- Do not subject the battery pack to high pressures.
- Do not place any objects on top of the battery pack.

BATTERY SAFETY INSTRUCTIONS



Over-voltages or wrong wiring can damage the Battery Pack and cause deflagration, which can be extremely dangerous. Do not install the battery pack on flammable construction materials, in areas, where highly inflammable materials are stored, or in potentially explosive environments. Work with the cover removed must be carried out by a qualified electrician. High contact voltages are present in the device.

8. Battery Handling Guide

- Do not expose battery to temperature over 50°C and open flame.
- Do not damage the unit in such ways as dropping, deforming, impacting, cutting or penetrating with a sharp object. It may cause a leakage of electrolyte or fire.
- Do not connect anode and cathode terminal block opposite direction.
 It may cause severe short circuits.
- Do not charge or discharge damaged battery.
- Do not place any kind of foreign matters on the cooling path.
- Do not put the battery module upside down on the ground.
- Hold with insulated gloves when carrying the battery modules.
- Do not disconnect, disassemble or repair by unauthorized persons. Services must be made by authorized engineers only.
- All types of breakdown of the product may lead to a leakage of electrolyte or flammable gas.
- Do not place the product nearby flammables. It may lead to fire or explosion in case of accident.
- Keep out of reach of children or animals.
- Keep the product away from moisture or liquid. Do not touch or use if liquid is spilled on the product.

8

Store at cool and dry place



9. Response to Emergency Situations

The RESU battery pack comprises multiple batteries that are designed to prevent hazards resulting from failures. However, LG Chem cannot guarantee their absolute safety.

Leaking batteries

If the battery pack leaks electrolyte, avoid contact with the leaking liquid or gas. Electrolyte is corrosive and contact may cause skin irritation and chemical burns. If one is exposed to the leaked substance, do these actions:

- Inhalation
 - : Evacuate the contaminated area, and seek medical attention immediately.
- Eye contact
 - : Rinse eyes with flowing water for 15 minutes, and seek medical attention immediately.
- Skin contact
 - : Wash the affected area thoroughly with soap and water, and seek medical attention immediately.
- Ingestion
- : Induce vomiting, and seek medical attention immediately.

Fire

In case of a fire, make sure that an ABC or carbon dioxide extinguisher is nearby. If a fire breaks out where the battery pack is installed, do these actions:

- Extinguish the fire before the battery pack catches fire.
- If the battery pack has caught fire, do not try to extinguish the fire. Evacuate people immediately.
 - * The battery pack may catch fire when heated above 150°C.
 If the battery catches fire, it will produce noxious and poisonous gases. Do not approach.

Wet batteries

If the battery pack is wet or submerged in water, do not try to access it. Contact LG Chem or your distributor for technical assistance.

Damaged batteries

Damaged batteries are dangerous and must be handled with extreme caution. They are not fit for use and may pose a danger to people or property. If the battery pack seems to be damaged, pack it in its original container, and then return it to LG Chem or your distributor.

* Damaged batteries may leak electrolyte or produce flammable gas. If you suspect such damage, immediately contact LG Chem for advice and information.



10. Troubleshooting

Check the indicators on the front to determine the state of the battery pack. A warning state is triggered when a condition, such as with voltage or temperature, is beyond design limitations. The battery pack's BMS periodically reports its operating state to the inverter.

When the battery pack falls outside prescribed limits, it enters a warning state. When a warning is reported, the inverter immediately stops operation. Use the monitoring software on the inverter to identify what caused the warning. The possible warning messages are as follows

- · Battery Over Voltage
- · Battery Under Voltage
- Battery Over Temperature
- Battery Under Temperature
- Battery Discharge Over Current
- Battery Charge Over Current
- BMS Internal Communication
- Battery Cell Voltage Imbalance

The abnormal state is cleared when the battery pack recovers normal operation.

* For a serious warning, if no proper corrective actions are taken by the inverter, the battery pack's circuit breaker automatically trips to protect itself.

10-1. Contact Information

Use the contacts below for technical assistance. These phone numbers are available only during business hours on weekdays.

	Telephone	Email
Europe	+49 162 2970918	aburkert@lgchem.com
USA	+1 248 808 0016	CSNorthAmericaESS@lgchem.com
Australia	+61 1300 178 064	m_AUservice@lgchem.com
Korea and Other regions	+82 43 219 2695	soongkyu@lgchem.com



