


# Certificate of Conformity

Certificate Number: CN-PV-200082

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced specifications /standards at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture. The manufacturer shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant Name & Address:	Shenzhen Growatt New Energy Technology CO.,Ltd 1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng Community, Shiyan Street, Baoan District, Shenzhen, P.R.China
Product Description:	PV Grid Inverter
Ratings & Principle Characteristics:	See Annex to Certificate of Conformity
Models/Type References:	Growatt 3000 TL3-S, Growatt 4000 TL3-S, Growatt 5000 TL3-S, Growatt 6000 TL3-S, Growatt 7000 TL3-S, Growatt 8000 TL3-S Growatt 9000 TL3-S, Growatt 10000 TL3-S, Growatt 11000 TL3-S
Brand Name:	Growatt
Specification/Standard:	EN 50549-1: February 2019, Requirements for generating plants to be connected in parallel with distribution networks Part 1: Connection to a LV distribution network - Generating plants up to and including Type B Compliant with COMMISSION REGULATION (EU) 2016/631 (NC RfG) Type approval for type B
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai 2/F (West Side), No. 707, Zhangyang Road, Free Trade Experimental Area, Shanghai, P. R. China
Test Report Number:	200109126GZU-001, Revision 1: 14 Jul 2020

Additional information in Appendix.



**Signature**

**Certification Manager: Grady Ye**

**Date: 17 July 2020**

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-200082

Ratings & Principle Characteristics:

Model	Growatt 8000 TL3-S	Growatt 9000 TL3-S	Growatt 10000 TL3-S	Growatt 11000 TL3-S	Growatt 7000 TL3-S
Input					
Max. PV Voltage:	1000Vdc				
Voltage range:	160-1000Vdc				
PV Isc:	16A/16A				
Output					
Nominal AC output voltage:	3W/N/PE 230Vac/400Vac				
Nominal frequency:	50 Hz				
Max power(VA):	8.8K	9.9K	11.0K	12.1K	7.7K
Max output current:	3*13.3A	3*15A	3*16.7A	3*18.3A	3*11.7A
Power factor:	0.8 Leading to 0.8 Lagging				
Ingress protection:	IP65				
Protection Class:	Class I				
Operation Ambient Temp	-25°C to +60°C				
Software Version	dhaa0101				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-200082

Ratings & Principle Characteristics:

Model	Growatt 3000 TL3-S	Growatt 4000 TL3-S	Growatt 5000 TL3-S	Growatt 6000 TL3-S
Input				
Max. PV Voltage:	1000Vdc			
Voltage range:	140-1000Vdc			
PV Isc:	16A/16A			
Output				
Nominal AC output voltage:	3W/N/PE 230Vac/400Vac			
Nominal frequency:	50 Hz			
Max power(VA):	3.0K	4.0K	5.0K	6.0K
Max output current:	3*4.5A	3*6.1A	3*7.6A	3*9.1A
Power factor:	0.8 Leading to 0.8 Lagging			
Ingress protection:	IP65			
Protection Class:	Class I			
Operation Ambient Temp	-25°C to +60°C			
Software Version	dhaa0101			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.