

CERTIFICATE OF COMPLIANCE

Certificate Number 20190404-E210376
Report Reference E210376-20190328
Issue Date 2019-APRIL-04


Issued to: SMA Solar Technology AG
Sonnenallee 1
34266 Niestetal GERMANY

**This is to certify that
representative samples of**

STATIC INVERTERS, CONVERTERS AND
ACCESSORIES FOR USE IN INDEPENDENT POWER
SYSTEMS

Permanently-connected, utility Interactive, 3-phase inverter,
Models: SHP 150-US-20, SHP 125-US-20. (which are
intended for DC input from photovoltaic modules)

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190404-E210376
Report Reference E210376-20190328
Issue Date 2019-APRIL-04

Standard(s) for Safety: UL1741 Standard for Safety for Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources.

UL 62109-1, Safety of power converters for use in photovoltaic power systems – Part 1: General requirements

IEEE 1547, IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems.

IEEE 1547.1, IEEE Standard for Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems.


CSA C22.2 No. 62109-1 Safety of power converters for use in photovoltaic power systems - Part 1: General requirements.

CSA C22.2 No. 62109-2 Safety of power converters for use in photovoltaic power systems - Part 2: Particular requirements for inverters.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: , may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190404-E210376
Report Reference E210376-20190328
Issue Date 2019-APRIL-04

Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for use as components of complete equipment submitted for investigation rather than for direct separate installation in the field. The final acceptance of the component is dependent upon its installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Permanently-connected, Grid Support Utility Interactive inverters.

This description covers the SMA Solar Technology AG Model: SHP 150-US-20, SHP 125-US-20. (which are intended for DC input from photovoltaic modules) inverters.


The Certificate is valid for the HP-Version V02.02.29.R.

USL - Evaluated to the requirements of the UL Standard for Safety of power converters for use in photovoltaic power systems – Part 1: General requirements, UL 62109-1 First Edition, Dated July 18, 2014.

Additionally evaluated to the requirements in UL 1741 Supplement SA (Second Edition, dated January 28, 2010, and revision dated February 15, 2018)– Grid Support Utility Interactive Inverters and Converters, Second Edition, dated September 7, 2016, which also fulfills the Source Requirement Documents of California Public Utilities Commission Rule 21 for grid support utility interactive inverters: the Generating Facility Interconnections of PG&E (Pacific Gas and Electric Company, Cal. P.U.C. Sheet No. 36812-E), SCE (Southern California Edison, Cal. PUC Sheet No. 60550-E) and SDG&E (San Diego Gas & Electric Company, Cal. P.U.C. Sheet No. 28143-E) and HECO SRD-UL-1741-SA-V1.1, 2017-09-22.

Additionally evaluated to the requirements in IEEE 1547 INTERCONNECTING DISTRIBUTED RESOURCES WITH ELECTRIC POWER SYSTEMS- Edition 1 - Revision Date 2014/05/16 and IEEE 1547.1 IEEE STANDARD CONFORMANCE TEST PROCEDURES FOR EQUIPMENT INTERCONNECTING DISTRIBUTED RESOURCES WITH ELECTRIC POWER SYSTEMS - Edition 1 - Revision Date 2015/03/26

CNL - Additionally evaluated to CSA C22.2 NO. 62109-1 SAFETY OF POWER CONVERTERS FOR USE IN PHOTOVOLTAIC POWER SYSTEMS - PART 1: GENERAL REQUIREMENTS - Edition 1 - Issue Date 2016/07/01 and CSA C22.2 NO. 62109-2 SAFETY OF POWER CONVERTERS FOR USE IN PHOTOVOLTAIC POWER SYSTEMS - PART 2: PARTICULAR REQUIREMENTS FOR INVERTERS- Edition 1 - Issue Date 2016/07/01



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190404-E210376
Report Reference E210376-20190328
Issue Date 2019-APRIL-04

Components covered by this certificate provide functionality in compliance with UL 1741 Supplement A (SA) when used in a UL Listed end product which has been evaluated by UL for its intended purpose. Compliance testing was conducted on samples of the products according to the test methods in the following sections of UL 1741 with compliant results:

(+)	Certified functions. Cross Reference table – UL 1741 SA to SRD	Source Requirement Document(s)	Test Standard(s) and Section(s)	Report Date
	ANTI-ISLANDING PROTECTION - UNINTENTIONAL ISLANDING WITH GRID SUPPORT FUNCTIONS ENABLED	N/A	UL 1741 SA 8	2019-03-28
	LOW/HIGH VOLTAGE RIDE- THROUGH	SRD 14H V1.1: Part II.C. Table 4	UL 1741 SA 9	2019-03-28
	LOW/HIGH FREQUENCY RIDE- THROUGH	SRD 14H V1.1: Part II.D.1 Table 5	UL 1741 SA10	2019-03-28
	RAMP RATES	SRD 14H V1.1: Part II.G.1	UL 1741 SA 11	2019-03-28
	RECONNECT BY "SOFT START"	SRD 14H V1.1: Part II.G.2	UL 1741 SA 11	2019-03-28
	SPECIFIED POWER FACTOR	SRD 14H V1.1: Part II.A.1	UL 1741 SA 12	2019-03-28
	DYNAMIC VOLT/VAR OPERATIONS	SRD 14H V1.1: Part II.A.2 Table 2, Figure 2	UL 1741 SA 13	2019-03-28
	FREQUENCY-WATT	SRD 14H V1.1: Part II.F Table 7	UL 1741 SA 14	2019-03-28
	VOLT-WATT	SRD 14H V1.1: Part II.B Table 3, Figure 3	UL 1741 SA 15	2019-03-28

(+) – Self Certification

Testing conducted to the requirements of UL 1741 SA corresponds to the minimum requirements for SRD-UL-1741-SA-V1.1. An enumeration of functions tested, including complete ratings, and available certified settings for the Grid Support functions, are recorded in the appendix to this document. Test data and detailed results of compliance testing are retained in the complete UL Report for this product.

B. Mahrenholz

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number 20190404-E210376
Report Reference E210376-20190328
Issue Date 2019-APRIL-04

Appendix

Detailed Testing Summary	Test Standard(s) and Section(s)	Fixed / Adjustable	Pass / Fail
UNINTENTIONAL ISLANDING WITH GRID SUPPORT FUNCTIONS ENABLED	UL 1741 SA 8	Adjustable	Pass
HIGH VOLTAGE RIDE-THROUGH DURATION	UL 1741 SA 9.1	Adjustable	Pass
HIGH VOLTAGE RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA 9.2	Adjustable	Pass
HIGH VOLTAGE MUST TRIP CLEARING TIMES	UL 1741 SA 9.2	Adjustable	Pass
LOW VOLTAGE RIDE-THROUGH DURATION	UL 1741 SA 9.1	Adjustable	Pass
LOW VOLTAGE RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA 9.2	Adjustable	Pass
LOW VOLTAGE MUST TRIP CLEARING TIMES	UL 1741 SA 9.2	Adjustable	Pass
HIGH FREQUENCY RIDE-THROUGH DURATION	UL 1741 SA10.1	Adjustable	Pass
HIGH FREQUENCY RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA10.2	Adjustable	Pass
HIGH FREQUENCY MUST TRIP CLEARING TIMES	UL 1741 SA10.2	Adjustable	Pass
LOW FREQUENCY RIDE-THROUGH DURATION	UL 1741 SA10.1	Adjustable	Pass
LOW FREQUENCY RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA10.2	Adjustable	Pass
LOW FREQUENCY MUST TRIP CLEARING TIMES	UL 1741 SA10.2	Adjustable	Pass
NORMAL RAMP RATE	UL 1741 SA 11.2	Adjustable	Pass
"SOFT START" RAMP RATE	UL 1741 SA 11.4	Adjustable	Pass
SPECIFIED POWER FACTOR	UL 1741 SA 12	Adjustable	Pass
VOLT/VAR MODE (Q(V))	UL 1741 SA 13	Adjustable	Pass
FREQUENCY-WATT (FW)	UL 1741 SA 14	Adjustable	Pass
VOLT-WATT (VW)	UL 1741 SA 15	Adjustable	Pass



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20190404-E210376
Report Reference E210376-20190328
Issue Date 2019-APRIL-04

Inverter Firmware Version:		
UL 1998	Date	Version/Revision
Compliant or N/A	2019-March-28	V02.02.29.R

Inverter Ratings - Output	All models, with individual differences as shown
Output phase configuration	3-Phase Delta
Nominal (line to line) output voltage V ac	480V / 600V
Operating voltage range V ac	422V – 528V / 480V – 690V
Line Synchronization Characteristics	Method 2
Normal out frequency Hz	60Hz
Rated output current (A ac)	145A / 151A
Rated output power, (kW)	125KW / 150KW
Max. Branch Circuit overcurrent protection (A ac)	250A
Maximum Air Ambient (°C)	60°C

Other ratings:	
Max. utility backfeed current to PV input (A)	0 A
Line Synchronization Characteristics / In-rush current	Method 2 / NA
Limits of accuracy of voltage measurement	+/- 2 %
Limits of accuracy of frequency measurement	+ /- 0.1 Hz
Manufacturers stated accuracy of time response for voltage trips	+ /- 0.1% of Tset
Manufacturers stated accuracy of time response for frequency trips	+ /- 0.1% of Tset
*Enclosure Ratings	Type 4X

INTERCONNECTION INTEGRITY TEST CATEGORIES:	
C62.42.2 Ring Wave Surge Category	B1 - / 5.87 kV / 0.5 kA
C62.42.2 Combination Wave Surge Category	B1 - Comb. Wave 6.27 kV @ 3.06 kA
C37.90.1 RF Immunity - compliance	Yes
C37.90.2 Communication circuit - compliance	Yes

B. Mahrenholz

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



Complete all fields highlighted in red.

GENERAL		
VALUE	INFORMATION	NOTES
Manufacturer	SMA Germany	
Model #	STP 125-US-20	List Applicable Model(s)
Firmware version	V02.02.29.R or higher	Provide applicable firmware
Certification / Self-Certification	Certified	Choose 1
NRTL Name	UL	
Certificate #	20190328-E210376-A	
SA Certification Date	28-03-2019	
Responsible Engineer	Christian Henss	
Report #	E210376-2019-03-28	

MANUFACTURER'S STATED ACCURACY						
VALUE	UNITS	RANGE	RATING		DESCRIPTION	
Model	unitless	-	SHP 125-US-20	-	-	Provide MSA for each model represented
Voltage, RMS	Volts	50 % < V ≤ 120 %	1%	-	-	
Current, RMS	Amps	100 %	1%	-	-	
Frequency	Hz	50 to 66 Hz	0.05	-	-	
Active Power	Watts	20 % < P ≤ 100 %	5%	-	-	
Reactive Power	VAR	20 % < Q ≤ 100 %	5%	-	-	
Power Factor	Displacement	20 % < P ≤ 100 %	0.01	-	-	
Time	s	100 ms to 600 s	0.001	-	-	

INVERTER DC (INPUT) SIDE

VALUE	RATING		UNITS	DESCRIPTION
	Min	Max		
$V_{DC\text{-rating}}$	705	1500	Volts	DC voltage rating
$V_{MPPT\text{-RANGE}}$	705	1450	Volts	Maximum power point track range
$I_{DC\text{ max}}$	325		Amps	Max input short-circuit current per MPPT

INVERTER AC (OUTPUT) SIDE					
VALUE	RATING		UNITS	DESCRIPTION	
$V_{AC\text{-NOMINAL(Phase-neutral)}}$	277	-	Volts	Nominal Voltage Phase-neutral (if neutral available)	
$V_{AC\text{-NOMINAL(Phase-phase)}}$	480	-	Volts	Nominal Voltage Phase-phase	
Number of Phases	3	-	Number	Number of electrical phases	
P_{OUT}	125000		VA	Rated Power Output	
$I_{NOMINAL\text{-OUTPUT}}$	151		Amps	Nominal current per phase	
$I_{MAXIMUM\text{-OUTPUT (at Vlow)}}$	151		Amps	Maximum output current at lowest operating voltage	

FIXED POWER FACTOR		480		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
		Min	Max	Min	Max	Min	Max				
>15 kW	Underexcited, Inductive, Absorbing	-80	100					%	-85% to 100%	Y	Capacitive (var injection) power factor to Reactive (var absorption) power factor range. RULE 14H Default PF = -0.95 (Absorbing) for self certification purposes.
	Overexcited, Capacitive, Injecting	100	80					%	100% to 85%	Y	
<=15 kW	Underexcited, Inductive, Absorbing	NA	NA					%	-90% to 100%	-	Capacitive (var injection) power factor to Reactive (var absorption) power factor range. RULE 14H Default PF = -0.95 (Absorbing) for self certification purposes.
	Overexcited, Capacitive, Injecting	NA	NA					%	100% to 90%	-	

VOLTAGE RIDE-THROUGH		480		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
		Min	Max	Min	Max	Min	Max				
OV2	$I_{RMS_MAX@VRT(V = 120\%)}$	125.29						Amps	-	-	Maximum RMS current when voltage goes above to 120% before trip
	$t_{TRIP(V > 120\%)}$	0.1	59.00					Sec.	0.16	Y	Trip time
OV1	$I_{RMS_MAX@VRT(V = 110\%)}$	136.68						Amps	-	-	Maximum RMS current when voltage is between 110% and 120% before trip
	$t_{RIDE-THROUGH(110\% < V \leq 120\%)}$	0.10	30					Sec.	0.92	Y	Ride through time
	$t_{TRIP(110\% < V \leq 120\%)}$	0.10	60.0					Sec.	1	Y	Trip time
Nominal	$I_{RMS_MAX@V(V = 109\%)}$	137.94						Amps	-	-	Maximum RMS current when voltage is 109%
	$I_{RMS@V(V = 100\%)}$	151.00						Amps	-	-	RMS current when voltage is 100%
	$I_{RMS_MIN@V(V = 90\%)}$	151.00						Amps	-	-	Minimum RMS current when voltage is 90%
UV1	$I_{RMS_MIN@VRT(V = 75\%)}$	151.00						Amps	-	-	Minimum RMS current when voltage is between 70% and 88% before trip
	$t_{RIDE-THROUGH(70\% \leq V < 88\%)}$	0.1	30					Sec.	20	Y	Ride through time
	$t_{TRIP(70\% \leq V < 88\%)}$	0.1	60.0					Sec.	21	Y	Trip time
UV2	$I_{RMS_MIN@VRT(V = 70\%)}$	151.00						Amps	-	-	Minimum RMS current when voltage is between 50% and 70% before trip
	$t_{RIDE-THROUGH(50\% \leq V < 70\%)}$	0.10	30					Sec.	10-20	Y	Ride through time
	$t_{TRIP(50\% \leq V < 70\%)}$	0.10	60.0					Sec.	11-21	Y	Trip time
UV3	$I_{RMS_MIN@VRT(V = 50\%)}$	151.00						Amps	-	-	Minimum RMS current when voltage is below 50% before trip
	$t_{RIDE-THROUGH(V < 50\%)}$	0.10	30					Sec.	-	-	Ride through time
	$t_{TRIP(V < 50\%)}$	0.10	60.0					Sec.	2	Y	Trip time

FREQUENCY RIDE-THROUGH		480		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
		Min	Max	Min	Max	Min	Max				
OF2	$I_{RMS_MAX@FRT(f = 64Hz)}$	151.00						Amps	-	-	Maximum RMS current when the frequency is above 64 Hz before trip
	$t_{TRIP(f > 64 Hz)}$	0.10	1000.00					Sec.	0.16	Y	Trip time
OF1	$I_{RMS_MAX@FRT(63 Hz < f \leq 64Hz)}$	151.00						Amps	-	-	Maximum RMS current when the frequency is between 63 and 64 Hz before trip
	$t_{RIDE-THROUGH(63 Hz < f \leq 64 Hz)}$	0.10	999					Sec.	20	Y	Ride Through Time
	$t_{TRIP(63 Hz < f \leq 64 Hz)}$	0.1	1000.0					Sec.	21	Y	Trip time
Nominal	$I_{RMS_MAX@f = 63 Hz}$	151.00						Amps	-	-	Maximum RMS current when the frequency is 63 Hz
	$I_{RMS@f = 60 Hz}$	151.00						Amps	-	-	RMS current when the frequency is 60 Hz
	$I_{RMS_MIN@f = 57 Hz}$	151.00						Amps	-	-	Minimum RMS current when the frequency is 57 Hz
UF1	$I_{RMS_MIN@FRT(56 Hz \leq f < 57 Hz)}$	151.00						Amps	-	-	Minimum RMS current when the frequency is between 56 and 57 Hz before trip
	$t_{RIDE-THROUGH(56 Hz \leq f < 57 Hz)}$	0.10	999					Sec.	20	Y	Ride Through Time
	$t_{TRIP(56 Hz \leq f < 57 Hz)}$	0.1	1000.0					Sec.	21	Y	Trip time
UF2	$I_{RMS_MIN@FRT(f < 56 Hz)}$	151.00						Amps	-	-	Minimum RMS current when the frequency is below 56 Hz before trip
	$t_{TRIP(f < 56 Hz)}$	0.1	1000					Sec.	0.16	Y	Trip time

Appendix A: Grid Support Utility Interactive Worksheet

VOLT-VAR, Q(V)	480		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
	Min	Max	Min	Max	Min	Max				
V1, UV _{Volt-Var_MIN}	70	100					% V _{NOMINAL}	94	Y	Lowest voltage where Volt-VAR starts at undervoltage
% Q1, VArS@UV _{Volt-Var_MIN}	-100	100					% Q (Var Injection)	44	Y	VArs at lowest undervoltage Volt-VAR point (-53% for aggregate generating facility >15 kW, -44% for aggregate generating facility <= 15 kW)
V2, UV _{Volt-Var_MAX}	70	100					% V _{NOMINAL}	97	Y	Highest voltage where Volt-VAR finish at undervoltage
% Q2, VArS@UV _{Volt-Var_MAX}	-100	100					% Q (0 VAr)	0	Y	VArs at highest undervoltage Volt-VAR point
V3, OV _{Volt-Var_MIN}	100	120					% V _{NOMINAL}	103	Y	Lowest voltage where Volt-VAR starts at overvoltage
% Q3, VArS@OV _{Volt-Var_MIN}	-100	100					% Q (0 VAr)	0	Y	VArs at lowest overvoltage Volt-VAR point
V4, OV _{Volt-Var_MAX}	100	120					% V _{NOMINAL}	106	Y	Highest voltage where Volt-VAR finish at overvoltage
% Q4, VArS@OV _{Volt-Var_MAX}	-100	100					% Q (Var Absorption)	-44	Y	VVArs at highest overvoltage Volt-VAR point (53% for aggregate generating facility >15 kW, 44% for aggregate generating facility <= 15 kW)
Response Time	0	1000					Sec.	10	Y	Response time (if non-adjustable range, place default value in MIN)
Power Priority	reactive						Unitless	Reactive	Y	Power Priority

POWER RAMP RATE	480		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
	Min	Max	Min	Max	Min	Max				
Connect/Reconnect RAMP _{RATE}	0.16	166					% P _{RATED} /sec.	100	Y	Percentage of nominal generated power per second "Ramp Rate"
Soft Start RAMP _{RATE}	0.016	166					% P _{RATED} /sec.	0.33	Y	Percentage of nominal generated power per second "Ramp Rate"

VOLT-WATT	480		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
	Min	Max	Min	Max	Min	Max				
Power Rate	0	100					% P _{RATED} /V	-25	Y	Percentage of power reduction per volt "Volt-Watt rate"
Start voltage	100	120					% V _{nom}	106	Y	Power reduction starting voltage
Stop voltage	100	120					% V _{nom}	110	Y	Power reduction endpoint voltage
Response Time	0	1000					Sec.	10	Y	Response time (If non-adjustable range, place default value in MIN)
Power Reference	P _{pre}						unitless	P _{rated} or P _{pre-disturbance}	Y	Active power output

FREQUENCY-WATT	480		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
	Min	Max	Min	Max	Min	Max				
FW _{RATE}	28.6	130					%P _{rated} /Hz	~42	Y	Minimum percentage of power reduction per hertz "frequency-watt rate" (based on KOF = 0.04)
Freq adjustment range at Start frequency	60.01	62					Hz	60.04	Y	Power reduction Starting Frequency (Based on dbOF = 0.036 Hz)
Response Time	3	3					Sec.	0.5 - 3	Y	Response time (if non-adjustable range, place default value in MIN)
Power Reference	P _{pre}						unitless	P _{rated} or P _{pre-disturbance}	Y	Active power output

METHODS FOR APPLYING SETPOINTS

Verify installed firmware version 02.02.29.R or higher

a. If necessary, download and install latest firmware version for SHP 125-US-20 and SHP 150-US-20 from SMA website

2. Set inverter operating parameters to comply with HECO Rule 14H GSUI requirements by manual parameter adjustments as described in SMA Technical Note US_TN_HECO_Rule_14H_SHP_US-20_PEAK3

Complete all fields highlighted in red.

GENERAL		
VALUE	INFORMATION	NOTES
Manufacturer	SMA Germany	
Model #	STP 150-US-20	List Applicable Model(s)
Firmware version	V02.02.29.R or higher	Provide applicable firmware
Certification / Self-Certification	Certified	Choose 1
NRTL Name	UL	
Certificate #	20190328-E210376-A	
SA Certification Date	28-03-2019	
Responsible Engineer	Christian Henss	
Report #	E210376-2019-03-28	

MANUFACTURER'S STATED ACCURACY						
VALUE	UNITS	RANGE	RATING		DESCRIPTION	
Model	unitless	-	SHP 150-US-20	-	-	Provide MSA for each model represented
Voltage, RMS	Volts	50 % < V ≤ 120 %	1%	-	-	
Current, RMS	Amps	100 %	1%	-	-	
Frequency	Hz	50 to 66 Hz	0.05	-	-	
Active Power	Watts	20 % < P ≤ 100 %	5%	-	-	
Reactive Power	VAR	20 % < Q ≤ 100 %	5%	-	-	
Power Factor	Displacement	20 % < P ≤ 100 %	0.01	-	-	
Time	s	100 ms to 600 s	0.001	-	-	

INVERTER DC (INPUT) SIDE

VALUE	RATING		UNITS	DESCRIPTION
	Min	Max		
$V_{DC\text{-rating}}$	880	1500	Volts	DC voltage rating
$V_{MPPT\text{-RANGE}}$	880	1450	Volts	Maximum power point track range
$I_{DC\text{ max}}$	325		Amps	Max input short-circuit current per MPPT

INVERTER AC (OUTPUT) SIDE					
VALUE	RATING		UNITS	DESCRIPTION	
$V_{AC\text{-NOMINAL(Phase-neutral)}}$	346	-	Volts	Nominal Voltage Phase-neutral (if neutral available)	
$V_{AC\text{-NOMINAL(Phase-phase)}}$	600	-	Volts	Nominal Voltage Phase-phase	
Number of Phases	3	-	Number	Number of electrical phases	
P_{OUT}	150000		VA	Rated Power Output	
$I_{NOMINAL\text{-OUTPUT}}$	145		Amps	Nominal current per phase	
$I_{MAXIMUM\text{-OUTPUT (at Vlow)}}$	151		Amps	Maximum output current at lowest operating voltage	

FIXED POWER FACTOR		600		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
		Min	Max	Min	Max	Min	Max				
>15 kW	Underexcited, Inductive, Absorbing	-80	100					%	-85% to 100%	Y	Capacitive (var injection) power factor to Reactive (var absorption) power factor range. RULE 14H Default PF = -0.95 (Absorbing) for self certification purposes.
	Overexcited, Capacitive, Injecting	100	80					%	100% to 85%	Y	
<=15 kW	Underexcited, Inductive, Absorbing	NA	NA					%	-90% to 100%	-	Capacitive (var injection) power factor to Reactive (var absorption) power factor range. RULE 14H Default PF = -0.95 (Absorbing) for self certification purposes.
	Overexcited, Capacitive, Injecting	NA	NA					%	100% to 90%	-	

VOLTAGE RIDE-THROUGH		600		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
		Min	Max	Min	Max	Min	Max				
OV2	$I_{RMS_MAX@VRT(V = 120\%)}$	120.28						Amps	-	-	Maximum RMS current when voltage goes above to 120% before trip
	$t_{TRIP(V > 120\%)}$	0.1	59.00					Sec.	0.16	Y	Trip time
OV1	$I_{RMS_MAX@VRT(V = 110\%)}$	131.22						Amps	-	-	Maximum RMS current when voltage is between 110% and 120% before trip
	$t_{RIDE-THROUGH(110\% < V \leq 120\%)}$	0.10	30					Sec.	0.92	Y	Ride through time
	$t_{TRIP(110\% < V \leq 120\%)}$	0.10	60.0					Sec.	1	Y	Trip time
Nominal	$I_{RMS_MAX@V = 109\%}$	132.42						Amps	-	-	Maximum RMS current when voltage is 109%
	$I_{RMS@V = 100\%}$	145.00						Amps	-	-	RMS current when voltage is 100%
	$I_{RMS_MIN@V = 90\%}$	151.00						Amps	-	-	Minimum RMS current when voltage is 90%
UV1	$I_{RMS_MIN@VRT(V = 75\%)}$	151.00						Amps	-	-	Minimum RMS current when voltage is between 70% and 88% before trip
	$t_{RIDE-THROUGH(70\% \leq V < 88\%)}$	0.1	30					Sec.	20	Y	Ride through time
	$t_{TRIP(70\% \leq V < 88\%)}$	0.1	60.0					Sec.	21	Y	Trip time
UV2	$I_{RMS_MIN@VRT(V = 70\%)}$	151.00						Amps	-	-	Minimum RMS current when voltage is between 50% and 70% before trip
	$t_{RIDE-THROUGH(50\% \leq V < 70\%)}$	0.10	30					Sec.	10-20	Y	Ride through time
	$t_{TRIP(50\% \leq V < 70\%)}$	0.10	60.0					Sec.	11-21	Y	Trip time
UV3	$I_{RMS_MIN@VRT(V = 50\%)}$	151.00						Amps	-	-	Minimum RMS current when voltage is below 50% before trip
	$t_{RIDE-THROUGH(V < 50\%)}$	0.10	30					Sec.	-	-	Ride through time
	$t_{TRIP(V < 50\%)}$	0.10	60.0					Sec.	2	Y	Trip time

FREQUENCY RIDE-THROUGH		600		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
		Min	Max	Min	Max	Min	Max				
OF2	$I_{RMS_MAX@FRT(f = 64Hz)}$	145.00						Amps	-	-	Maximum RMS current when the frequency is above 64 Hz before trip
	$t_{TRIP(f > 64 Hz)}$	0.10	1000.00					Sec.	0.16	Y	Trip time
OF1	$I_{RMS_MAX@FRT(63 Hz < f \leq 64Hz)}$	145.00						Amps	-	-	Maximum RMS current when the frequency is between 63 and 64 Hz before trip
	$t_{RIDE-THROUGH(63 Hz < f \leq 64 Hz)}$	0.10	999					Sec.	20	Y	Ride Through Time
	$t_{TRIP(63 Hz < f \leq 64 Hz)}$	0.1	1000.0					Sec.	21	Y	Trip time
Nominal	$I_{RMS_MAX@f = 63 Hz}$	145.00						Amps	-	-	Maximum RMS current when the frequency is 63 Hz
	$I_{RMS@f = 60 Hz}$	145.00						Amps	-	-	RMS current when the frequency is 60 Hz
	$I_{RMS_MIN@f = 57 Hz}$	145.00						Amps	-	-	Minimum RMS current when the frequency is 57 Hz
UF1	$I_{RMS_MIN@FRT(56 Hz \leq f < 57 Hz)}$	145.00						Amps	-	-	Minimum RMS current when the frequency is between 56 and 57 Hz before trip
	$t_{RIDE-THROUGH(56 Hz \leq f < 57 Hz)}$	0.10	999					Sec.	20	Y	Ride Through Time
	$t_{TRIP(56 Hz \leq f < 57 Hz)}$	0.1	1000.0					Sec.	21	Y	Trip time
UF2	$I_{RMS_MIN@FRT(f < 56 Hz)}$	145.00						Amps	-	-	Minimum RMS current when the frequency is below 56 Hz before trip
	$t_{TRIP(f < 56 Hz)}$	0.1	1000					Sec.	0.16	Y	Trip time

Appendix A: Grid Support Utility Interactive Worksheet

VOLT-VAR, Q(V)	600		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
	Min	Max	Min	Max	Min	Max				
V1, UV _{Volt-Var_MIN}	70	100					% V _{NOMINAL}	94	Y	Lowest voltage where Volt-VAR starts at undervoltage
% Q1, VArS@UV_Volt-Var_MIN	-100	100					% Q (Var Injection)	44	Y	VArS at lowest undervoltage Volt-VAR point (-53% for aggregate generating facility >15 kW, -44% for aggregate generating facility <= 15 kW)
V2, UV _{Volt-Var_MAX}	70	100					% V _{NOMINAL}	97	Y	Highest voltage where Volt-VAR finish at undervoltage
% Q2, VArS@UV_Volt-Var_MAX	-100	100					% Q (0 VAr)	0	Y	VArS at highest undervoltage Volt-VAR point
V3, OV _{Volt-Var_MIN}	100	120					% V _{NOMINAL}	103	Y	Lowest voltage where Volt-VAR starts at overvoltage
% Q3, VArS@OV_Volt-Var_MIN	-100	100					% Q (0 VAr)	0	Y	VArS at lowest overvoltage Volt-VAR point
V4, OV _{Volt-Var_MAX}	100	120					% V _{NOMINAL}	106	Y	Highest voltage where Volt-VAR finish at overvoltage
% Q4, VArS@OV_Volt-Var_MAX	-100	100					% Q (Var Absorption)	-44	Y	VVArS at highest overvoltage Volt-VAR point (53% for aggregate generating facility >15 kW, 44% for aggregate generating facility <= 15 kW)
Response Time	0	1000					Sec.	10	Y	Response time (if non-adjustable range, place default value in MIN)
Power Priority	reactive						Unitless	Reactive	Y	Power Priority

POWER RAMP RATE	600		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
	Min	Max	Min	Max	Min	Max				
Connect/Reconnect RAMP _{RATE}	0.16	166					% P _{RATED} /sec.	100	Y	Percentage of nominal generated power per second "Ramp Rate"
Soft Start RAMP _{RATE}	0.016	166					% P _{RATED} /sec.	0.33	Y	Percentage of nominal generated power per second "Ramp Rate"

VOLT-WATT	600		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
	Min	Max	Min	Max	Min	Max				
Power Rate	0	100					% P _{RATED} /V	-25	Y	Percentage of power reduction per volt "Volt-Watt rate"
Start voltage	100	120					% V _{nom}	106	Y	Power reduction starting voltage
Stop voltage	100	120					% V _{nom}	110	Y	Power reduction endpoint voltage
Response Time	0	1000					Sec.	10	Y	Response time (If non-adjustable range, place default value in MIN)
Power Reference	P _{pre}						unitless	P _{rated} or P _{pre-disturbance}	Y	Active power output

FREQUENCY-WATT	600		-		-		UNITS	SRD V1.1 Range	SRD V1.1 Compliant?	DESCRIPTION
	Min	Max	Min	Max	Min	Max				
FW _{RATE}	28.6	130					%P _{rated} /Hz	~42	Y	Minimum percentage of power reduction per hertz "frequency-watt rate" (based on KOF = 0.04)
Freq adjustment range at Start frequency	60.01	62					Hz	60.04	Y	Power reduction Starting Frequency (Based on dbOF = 0.036 Hz)
Response Time	3	3					Sec.	0.5 - 3	Y	Response time (if non-adjustable range, place default value in MIN)
Power Reference	P _{pre}						unitless	P _{rated} or P _{pre-disturbance}	Y	Active power output

METHODS FOR APPLYING SETPOINTS

Verify installed firmware version 02.02.29.R or higher

a. If necessary, download and install latest firmware version for SHP 125-US-20 and SHP 150-US-20 from SMA website

2. Set inverter operating parameters to comply with HECO Rule 14H GSUI requirements by manual parameter adjustments as described in SMA Technical Note US_TN_HECO_Rule_14H_SHP_US-20_PEAK3